

प्रथमा बैंक
मुख्य कार्यालय
रामगंगा विहार, फेज-2
मुरादाबाद-244001 (उ०प्र०)



Prathama Bank
Head Office
Ram Ganga Vihar Ph-II
MORADABAD- 244 001(U.P.)

PREMISES & MAINTENANCE DEPTT.

PBHO/PMD/ 1098 /2014,

Dt.25.07.2014

Sri Jatin Grover,
M/s Ritika Systems Pvt. Ltd.,
C22/18, Sector-57,
NOIDA (UP) 201301

Dear Sir,
Sub.: Suplly, Installation & commissioning of
40 Solar Power Solutions.
Ref. :: Your Email, dt.19.07.2014

Please note our remarks as follows :

Point No. 1- As per Tender Page No.4, point No. 1- scope of work
Point No. 2- Minimum capacity of Battery Bank-
96 V – 600 AH @ C10

With regards.

General Manager